



United States Steel Corporation  
Clairton Works  
400 State Street  
Clairton, PA 15025

42-003-00032

RECEIVED  
DEC 18 2013

3AP20

December 6, 2013

Ms. Gail Eddings  
Allegheny County Health Department  
Department of Air Quality  
301 Thirty-Ninth Street  
Pittsburgh, PA 15201


Subject: USS Reference Number: 13-0236  
ACHD Reference Number: 16592  
Sulfur Plant  
USS Clairton Works

Dear Gail Eddings,

The attached form confirms our verbal report of the subject incident and satisfies the requirements of paragraph IV.8 of the Title V operating permit #0052 as issued on March 27th 2012.

I certify that based on the information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete. Any questions concerning this matter should be referred to Coleen M. Davis at 412-233-1015.

Sincerely,

  
Thomas E. Schumacher  
Plant Manager  
Clairton Works

CC: James W. Hagedorn (USEPA)

NOTICE OF OUTAGE OF EQUIPMENT  
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 13-0236  
ACHD Reference Number: 16592
2. Date & Time of Breakdown: Date: 12/06/13 Time: 0945 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: Sulfur Plant
5. BAPC Permit Number (if applicable):
6. Location: Clairton, PA
7. Nature and cause of breakdown: The 40 grain H<sub>2</sub>S limit at the Sulfur Plant was momentarily exceeded when the 663A Lean Carbonate solution pump failed.
8. Identification of Emissions:
  - A. Type(s) (CO, NOX, SO<sub>2</sub>, Particulates, Hydrocarbons, etc.)  
Elevated H<sub>2</sub>S in the down river gas line system, causing increased SO<sub>2</sub> at points of combustion.
  - B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). SO<sub>2</sub> is an eye, nose, and throat irritant.
  - C. Amount of each type emitted (or likely to be emitted).  
Light
9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).  
The spare 663B pump was placed in service while repairs were performed on the 663A pump.
10. Facility back in operation - Date: 12/06/13 Time: 1005 hours

Reviewed by

  
James Hosfield

Environmental Control Engineer

Date

2013-12-06

Phone: 412-233-1468